

STEAM CONDENSATE RECOVERY OPPORTUNITY:

Museum Main Building steam condensate is being discharged to sewer. The plumbing code requires that the condensate be cooled before being discharged to the sewer. This cooling is being done by mixing potable water with the condensate. This cost saving opportunity is to use the water being sent to drain for makeup water in the cooling towers. This opportunity would result in water, and sewer cost savings.

Given Data:

Water Rate \$3.81/1000 gallons
 Sewer Rate \$4.34/1000 gallons
 Steam/Energy Rate \$20.54/1000 pounds
 Electric Rate \$0.0553/KWH
 Annual Operating Hours (AOH) 8760
 Annual Steam Consumed (ASC)
 Average Steam Flow 9,178 pounds/hour

$$\text{WaterCost} := \frac{3.81 \cdot \$}{1000 \cdot \text{gal}}$$

$$\text{SewerCost} := \frac{4.34 \cdot \$}{1000 \cdot \text{gal}}$$

$$\text{FuelCost} := \frac{20.54 \$}{10^6 \cdot \text{Btu}}$$

$$\text{AOH} := 8760 \cdot \text{hr}$$

$$\text{ElectricCost} := \frac{0.0553 \$}{\text{kW} \cdot \text{hr}}$$

Assumptions:

1. Condensate is equal to 67% of steam use in 2016-2017 due to steam losses from steam vents and humidification steam and proposed reductions in the number of steam heating coils.
2. Condensate water recovery can be used in cooling towers.
3. Condensate Temperature 180 F.
4. Potable Water Temperature 55 F.
5. Condensate is cooled to 110 F for sewer discharge.
6. Cooling tower condenser water flow rate, 2800 GPM (TFR).
7. Cooling tower cycles of concentration, 3 (C).
8. Cooling tower drift rate, 0.005%, (D)
9. Cooling tower operating power, 0.4 kW/ton, (TP)
10. Evaporation Rate 1% of flow rate.
11. Cooling tower condenser water supply temperature to chiller, 75 F.

$$\text{ASC} := 9178 \cdot \frac{\text{lb}}{\text{hr}} \cdot \text{AOH}$$

$$\text{Condensate} := 0.67 \cdot \frac{\text{ASC}}{8.34 \cdot \frac{\text{lb}}{\text{gal}}}$$

$$\text{Condensate} = 6458935 \text{ gal}$$

$$\text{TFR} := 2800 \cdot \frac{\text{gal}}{\text{min}}$$

$$C := 3 \quad D := 0.00005$$

$$\text{TP} := 0.4 \cdot \frac{\text{kW}}{12000 \cdot \frac{\text{Btu}}{\text{hr}}}$$

Cooling Tower Water Use (TWU):

$$Evaporation := 0.01 \cdot TFR \qquad Evaporation = 28 \frac{\text{gal}}{\text{min}}$$

$$Blowdown := \frac{Evaporation}{(C-1)} \qquad Blowdown = 14 \frac{\text{gal}}{\text{min}}$$

$$Drift := D \cdot TFR \qquad Drift = 0.14 \frac{\text{gal}}{\text{min}}$$

$$TWU := Evaporation + Blowdown + Drift \qquad TWU = 42.14 \frac{\text{gal}}{\text{min}}$$

Condensate Cooling Water/Sewer (CWS):

Cooling water and sewer required to cool condensate from 180 F to 110 F using potable water at 55 F. Required by plumbing code before condensate can be sent to drain system.

$$CWS := \frac{Condensate}{AOH} \left(\frac{180 - 110}{110 - 55} \right) \qquad CWS = 15.64 \frac{\text{gal}}{\text{min}} \qquad CWS \cdot AOH$$

$$CWS \cdot AOH = (8.22 \cdot 10^6) \text{ gal}$$

Available Cooling Water plus Condensate (AW):

$$AW := CWS + \frac{Condensate}{AOH} \qquad AW = 27.929 \frac{\text{gal}}{\text{min}}$$

Annual Water/Sewer Cost Savings:

$$WaterSewerCost\$:= WaterCost\$ + SewerCost\$$$

$$Savings\$:= CWS \cdot AOH \cdot (WaterSewerCost\$) + Condensate \cdot (WaterSewerCost\$)$$

$$Savings\$ = (1.196 \cdot 10^5) \$ \qquad \$119,637.09$$

Electric cost to run water pumps to pump condensate to tower \$ (EC) :

Pump break horsepower, GPM=pump gallons per minute, TDH=pump total dynamic head feet water, SG=specific gravity of water 1 and E= pump efficiency 50 percent

$$TDH := 115 \qquad SG := 1 \qquad E := 0.5$$

$$gpm_{avg} := 27.93 \qquad BHP_{pump} := \frac{gpm_{avg} \cdot TDH \cdot SG}{3960 \cdot E} \qquad BHP_{pump} = 1.622$$

$$EC_{PC} := (BHP_{pump}) \cdot 0.746 \text{ kW} \cdot AOH \cdot ElectricCost\$ \qquad EC_{PC} = 586.235 \$$$

$$PumpElectric := BHP_{pump} \cdot 0.746 \cdot \text{kW} \qquad PumpElectric = 1.21 \text{ kW}$$

Cooling tower energy required for cooling condensate CTE:

$$CTE := 27.93 \cdot 500 \cdot (110 - 75) \cdot \frac{\text{Btu}}{\text{hr}} \cdot TP \quad CTE = 16.293 \text{ kW}$$

$$EC_{CT} := CTE \cdot AOH \cdot \text{ElectricCost\$} \quad EC_{CT} = (7.893 \cdot 10^3) \$$$

Net Annual Cost Savings \$ (NAS):

$$NAS := \text{Savings\$} - (EC_{PC} + EC_{CT}) = (1.112 \cdot 10^5) \$ \quad \$111,200.00$$

Net Annual Water and Sewer Savings (Water/Sewer):

$$\text{WaterSewer} := CWS \cdot AOH + \text{Condensate} \quad \text{WaterSewer} = (1.468 \cdot 10^7) \text{ gal}$$

Net Annual Increase in Electric Use (EU):

$$EU := (\text{PumpElectric} + CTE) \cdot AOH \quad EU = (1.533 \cdot 10^5) \text{ kW} \cdot \text{hr}$$

SUMMARY:

ANNUAL COST SAVINGS: \$111,200.00
 ANNUAL WATER SAVINGS: 14,680,000 GALLONS
 ANNUAL SEWER SAVINGS: 14,680,000 GALLONS
 ANNUAL INCREASE IN ELECTRIC USE: 153,300 KWH